



PERMIT TO CONSTRUCT
Onsite Wastewater System

File Nbr **2019100007**
County: Newberry

Name: BEN SATCHER

Type Facility: HOUSE

Subdivision:

Block: Lot: 4

Address: PO BOX 888
LEXINGTON, SC 29071

Site: ST. LUKE'S CHURCH RD LOT 4
PROSPERITY, SC

Program Code: 360

System Code: 233

TM#: 411-47

Water Supply: PRIVATE

PERMIT TO CONSTRUCT SYSTEM SPECIFICATIONS

Daily Flow (gpd): 480

Tank Sizes (gal): Septic Tank: 1000 Pump Chamber: 500

Grease Trap:

LTAR: .30

Trenches: Length (ft): 520 Width (in): 36 Max. Depth (in): 24

Agg. Depth (in):

Min Pump Capacity: 10 gpm at

ft. of Head

Inf./low profile

SPECIAL INSTRUCTIONS/CONDITIONS

THIS PERMIT IS SITE SPECIFIC. ANY CHANGES TO THE SYSTEM MUST BE APPROVED BY DHEC. ALTERNATIVE TRENCH PRODUCTS APPROVED UNDER STATE RULES AND REGULATIONS MAY BE SUBSTITUTED. ANY UNAPPROVED CHANGES WILL VOID THIS PERMIT.

- All applicable setbacks set forth in Regulation 61-56 apply.
- Maximum Trench Depth not to exceed 24 inches. Place lines on contour and use serial distribution if needed.
- Do not install under wet soil conditions. Minimum 9" cover over system after installation.
- This system is designed for specific quantities of domestic wastewater ONLY.
- Do not cut, fill, bulldoze, scrape or change the grade of the natural soils in the septic system area.
- No parking, driving, building or paving over the area of septic system before or after installation.
- Pre-construction conference required for property owners who wish to install their own system.

PERMIT TO CONSTRUCT SYSTEM DIAGRAM

X (NTS) X

** See supplemental form*

Issued/Revised By: *W.A. [Signature]*

Date: 1/27/20

DHEC 1781 (01/2014)

This Permit is Appealable Under the Administrative Procedures Act.
There may be an Additional Fee for Changes in this Permit that Require a Site Reevaluation.



APPLICATION SUPPLEMENTAL FORM

Onsite Wastewater System

File Nbr: 2019100007

County: Newberry

Name: BEN SATCHER

Address:

PO BOX 888
LEXINGTON, SC 29071

Program Code: 360

Type Facility: HOUSE

TM#: 411-47

Subdivision

Site: ST. LUKE'S CHURCH RD LOT 4
PROSPERITY, SC

Water Supply: PRIVATE

Block:

Lot: 4

**Not to scale*

**No further reduction is allowed.*

**Area where drainfield is marked w/ blue tape.*

**Stay 25' min from drainage ditches, stay 75' min from creek.*

**Drainfield MUST BE in area drawn, all other soil is not suitable.*

